

**NOTE**  
 CONTRACTOR TO COORDINATE WITH FIRE MARSHALL'S OFFICE AT BEGINNING OF CONSTRUCTION TO DETERMINE NUMBER AND LOCATION OF REQUIRED FIRE RELATED SIGNAGE PAINTING & STRIPING- INCLUDE THIS COST WITH BIDS.

**MARKING**  
 Section 503.1.1.1 FIRE APPARATUS ACCESS ROADS. Amend to read as follows: Upon the designation of a fire lane pursuant to this ordinance, the Fire Chief shall give notice of such designation to the owner of such designated premise, directing the owner to cause signs to be posted at the expense of the owner, at designated locations, lettered "Fire Lane-No Parking at any Time. Ord. 54547". Such signs shall be of standard size and color, of standard lettering and mounting, conforming to specifications established by the Director of Public Works. In addition to the signs, the owners of such designated premises at their option, or, if so directed by the Fire Chief shall paint all fire lane curbs red with white-stenciled letters stating "Fire Lane, No Parking". Lettering for the curbs shall use four (4) inch lettering with a distance of not more than forty (40) feet between wordings. It shall be unlawful to park any vehicle other than an authorized emergency vehicle in a designated fire lane when such signs are in place or such red curbing exists. In areas where the fire lane may not be clearly defined, the Fire Chief may require a four (4) inch red stripe be painted that defines the boundaries of the fire lane.

**Signs: See diagram**


1. Under the guidelines and restrictions of the City Fire Lane Ordinance, (54547, Section 15-82.4) an independent contractor may install the standard size sign only on non city property identified as "designated premises" in Section 202 of San Antonio Code.
2. Signs installed by the City of San Antonio shall only be of the standard size (18" x 24"), as specified by Texas Manual on Uniform Traffic Control Devices for Streets and Highways-code R7-35.
3. Signs should have RED letters and border on a WHITE background.
4. For a designated fire lane less than forty (40) feet: One (1) sign with a double arrow.
5. For a designated fire lane from forty (40) feet to ninety (90) feet: two (2) signs with right and left arrows.
6. For a designated fire lane of one hundred (100) feet or more: three (3) signs with right/left and double arrows in the middle.
7. The bottom edge of the sign must be at least seven (7) feet above grade where the sign is installed and at least two (2) feet from the curb edge.
8. After application and plan submittal, a fire plan reviewer of fire inspector will identify the location and number of all signs required.



REVISED ISSUE DATES:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**BUSH'S CHICKEN**  
 1550 STATE HWY 46  
 BOERNE, TX.

**FIRE PROTECTION PLAN**



PROJECT NO. 31367-BOERNE  
 ISSUE DATE: 06-01-16  
 DRAWN BY: RT  
 REVIEWED BY: RAL

Date: Jun 01, 2016, 2:01pm User: D:\namez Layout: FIRE PROTECTION PLAN File: F:\31367-Boerne\31367-Boerne\Fire Protection\31367.dwg Layout name: FIRE PROTECTION PLAN