TEXAS REGISTERED ENGINEERING FIRM F-10487 700 N. ST. MARY'S
SUITE 1225
SAN ANTONIO, TX 78205
WWW.RGMENGINEERING.NET
PHONE: 210.299.4522 FAX: 210.299.4525

ALL EXPOSED DUCTWORK SHALL BE "PAINT GRIP" COATED AND PAINTED BLACK.

- RTU ON ROOF REFER TO DETAIL AND SCHEDULE. PROVIDE STRUCTURAL SUPPORTS AS REQUIRED TO SUPPORT UNIT. ROUTE 3/4" CONDENSATE WITH TRAP AS INDICATED TO JANITORS SINK
- 2 PROGRAMMABLE THERMOSTAT MOUNTED AT ADA COMPLIANT HEIGHT.

- (5) DROP 3/4" COPPER CONDENSATE FROM ROOF TO JANITORS SINK. COORDINATE ROOF PENETRATION WITH ROOFING CONTRACTOR TO

MECHANICAL GENERAL NOTES:

MECHANICAL KEYED NOTES:

- AS INDICATED.
- (3) EXHAUST FAN REFER TO DETAIL AND SCHEDULE.
- GRAVITY HOOD ON ROOF REFER TO SCHEDULE. INSTALL 10'-0" FROM ALL OUTSIDE AIR VENTS.
- MAINTAIN WARRANTY.
- (6) RETURN AIR PLENUM.

MECHANICAL FLOOR PLAN

BABCOCK, ANTONIO,

23 AN

48

9

DURAND-HOLLIS RUPE ARCHITECTS, INC.


14603 HUEBNER RD.

TEL. 210 308-0080 FAX. 210 697-3309

email office@dhrarchitects.com

BUILDING 18 SAN ANTONIO, TEXAS 78230


THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY ROGER G. MENDEZ, P.E. 93809



THIS DRAWING IS PROVIDED AS AN INSTRUMENT OF SERVICE BY THE ENGINEER AND IS INTENDED FOR USE ON THIS PROJECT ONLY. THE DRAWING REMAINS THE PROPERTY OF THE ENGINEER AND SHALL BE RETURNED TO HIM/HER UPON COMPLETION OF THE CONSTRUCTION WORK. PURSUANT TO THE ENGINEER WORKS COPYRIGHT PROTECTION ACT OF 1990, ALL DRAWINGS, SPECIFICATIONS, IDEAS AND DESIGNS, INCLUDING THE OVERALL FORM, ARRANGEMENT AND COMPOSITION OF SPACES AND ELEMENTS APPEARING HEREIN, CONSTITUTES THE COPYRIGHTED WORK OF THE ENGINEER. ANY REPRODUCTION, USE, OR DISCLOSURE OF INFORMATION CONTAINED HEREIN WITHOUT PRIOR WRITTEN CONSENT OF THE ENGINEER IS STRICTLY PROHIBITED. © 2015

PROJECT NO. 16-014 ISSUE DATE: 04-01-16 DRAWN BY: RGM REVIEWED BY: RGM PROJECT ARCHITECT: GABRIEL DURAND—HOLLIS, FAIA TEXAS LICENSE NO. 10881

M101



4 GH-1

(1470 LBS.)

