



ADDENDUM NO. 4 – Geotech Revisions

VP PROJECT NO. 2017-100:

TEXAS PLUMBING SUPPLY

35,100 SF Office/Warehouse Building

17992 Red Iron

Schertz, Texas 78154

The contract documents noted on sheet TP1 dated May 15, 2017 shall be clarified, revised, added to, or deleted from according to the following:

ARCHITECTURAL

STRUCTURAL

Sheet S2.0 RTU location and weight has been added to the roof framing plan for the design of the joists and joist girders.

Sheet S3.0 Detail 1/S3.0 revised to show the vertical moisture barrier on the face of the footing or lean concrete backfill per the revised geotechnical recommendations.

END ADDENDUM #4